

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182609
Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Monday, April 06, 2020

Partial Correction:

1	ELEVATOR 1	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT: 1ST LAYER 1-4, 2nd layer, ceiling 2nd;3rd,4
---	------------	---

Corrective Action Required:

2	STAIR TOWER 1	SPACES BETWEEN JOISTS AT BACKSIDE: 3RD FLOOR 1ST BASEMENT- EXTERIOR: 4TH FL- CEILING complete INTERIOR SIDE: 4TH FL-1ST LAYER;2ND BASEMENT-1ST LAYER OK
---	---------------	---

Corrective Action Required:

3	STAIR TOWER 2	OUTER SIDE: SPACES BETWEEN JOISTS AT BACKSIDE: 3RD- FLOOR 1ST
---	---------------	---

CEILING complete-

INTERIOR SIDE:

4TH FL-1ST LAYER;2ND

BASEMENT-1ST LAYER OK

Corrective Action Required:

4 FOURTH FLOOR

Pre rock tub & showers 4th floor approved 1ST 2ND AT STAIR TOWNERS

Corrective Action Required:

5 THIRD FLOOR

Pre rock tub & showers 3rd floor approved

Corrective Action Required:

6 SECOND FLOOR

TUB SHOWERS - 1ST; 2ND Layer

Corrective Action Required:

7 FIRST FLOOR

TUB SHOWERS - 1ST; 2ND Layer

Corrective Action Required:

8 LOWER LEVEL

Elevator Equip, IT, Electrical rooms-2nd layer ok

Comments: