

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193433
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	Joe Starlin	Partial	Monday, April 06, 2020

Informational:

1	Misc	1-31-20 9:28am Kat Excavation is doing the work. They have ran the 2" waterline into the meter and out to the building. The meter is set. They have rocked and backfilled the majority of the line.
---	------	---

Informational:

2	Misc	4-6-20 10:59am They are flushing the fire line. They flushed for approximately 15 minutes.
---	------	--

Comments: