

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20191809
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064
Inspected On: Monday, April 06, 2020
Inspected By: Khanh Nguyen
Expiration Date: 1/27/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Monday, April 06, 2020

Corrective Action Required:

- 1 Misc
-Approval from the following departments required: Planning, and Field Service
-Install sewer cleanout plugs for both sanitary and grease drain