

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170397

Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Failed	Monday, April 06, 2020

Corrective Action Required:

1	Misc	- 3rd floor screw pattern - # 311 replace type X on ceiling with type C ft door , bed, bath, closet - # 309 replace type X on ceiling with type C bedroom - - Southwest Stairways lids only
---	------	---

Comments: