

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Mark Harding	Partial	Monday, April 06, 2020

Partial Correction:

1 Misc

LIGHT POLE PIERS/PADS APPROVED TO POUR:
-2 NORTH AND SOUTH LP PEDESTALS AND PADS ON THE EAST SIDE PARKING LOT; ONE LP ON THE NORTH SIDE OF BUILDING, 3 WEST PIERS

Corrective Action Required:

2 Misc

EAST LP PIER AT EAST PARKING LOT IS NOT MIN. 11 FT PER DESIGN. HAVE ENGINEER ADDRESS
EMAIL ENG REPORT ON FIX.
EAT CENTER AND NORTH POLE.

NOTE-ONLY3 REMAINING ON WEST SIDE

Comments: