

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182264
Address: 1833 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, April 07, 2020

Corrective Action Required:

1	Misc	- PROVIDE ACCESS TO JACUZZI TUB MOTOR - - PROVIDE LAWN IRRIGATION PERMIT AND SUBMIT BACKFLOW CERTIFICATION - - PROVIDE 6" GRADE TO SIDING - - ROUGH IN FAILED OPEN ITEM = PROVIDE ANCHOR BOLT WITHIN 12" OF PLATE BREAK EAST SIDE OF GARAGE -
---	------	--

Comments: