

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192994
Address: 4401 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, April 07, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- covered deck shall have 1 roof vent 4 soffit vents per plan 4.00 -- complete roof & flashing above porch & garage -- seal bore bottom plate bed # 5 -- provide PFH portal frame garage door per plan --Anchor bolts shall be in middle 1/3 of plate width garage -provide blocking sheathing break under window bed # 2 -- provide anchor bolt at plate break rear wall basement-- seal exterior penetration at elec box rear wall basement -
---	------	--

Comments: