

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192672
Address: 1534 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Commercial Curb Inspection	John DiMauro	Passed	Tuesday, April 07, 2020

Informational:

1 Misc

K&E Flatwork is on site installing the curbs for the parking lot. I verified that they are using the correct concrete type and that the forms are set up according to the approved plans. Photos of the work will be uploaded to the system.

Informational:

2 Misc

Final curb inspection.

The parking lot curb has been installed and appears to match the approved plans. The crew grouted the back of the curbs today in the areas that had honeycomb. The ADA sections of the curb appear to be in compliance. Curbs are acceptable.

Comments: