

Inspection Summary

Permit #: PRSITE20192599, Development - Site
ATTIC STORAGE OF LEES SUMMIT
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Wye / Insert-A-Tee Installation Informational	Steve Robbins	Passed	Tuesday, April 07, 2020
1	The contractors installed a wye on the main. I appeared to be at no more than 45 and not less than 30.		

Comments: