## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20172513

Address: 229 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Michael Harkins Failed Wednesday, April 08,

Commercial 2020

Corrective Action Required:

2 Misc - G6-12 SELF CLOSING DOOR -

- G6-8 REPAIR CEILING -

- G6-9 HANDRAIL -

G6-6 COMPLETE FURR OUT -G6-1 SELF CLOSING DOOR -201 ANTI TIP DEVICE RANGE -

- FIRE ALARM PANEL ROOM FIRE CAULKING -

- EAST END GFCI AT EXTERIOR HVAC NO POWER -

- EAST END INSTALL A/C CONDENSORS -

- PROVIDE TAMPER PROOF CAPS ALL A/C CONDENSORS - COMPLETE WIRING & LABEL ALL A/C DISCONNECTS -

- FIRE CAULK PLUMBING PENETRATIONS AT ALL WATER HEATERS -

**Comments:**