

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20170397  
Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Failed	Wednesday, April 08, 2020

Informational:

1 Misc

Bldg # 1 -

-

3rd floor all rough complete -

- 2nd Floor  
complete

NE NW SW SE stairways 3rd & 2nd floors complete

Corrective Action Required:

2 FIRST FLOOR

4/8/20 reinspect

- 104 fire caulk bore top plate bedroom near bath, -

- - 108 address notched truss at dryer vent Addressed by letter stamped by Robert A Davis PE. -

**Comments:**