
RESIDENTIAL ENGINEERING SERVICES, LLC SHOP DRAWING / SUBMITTAL REVIEW

APPROVED

SUBMITTAL WAS REVIEWED FOR DESIGN CONFORMITY AND GENERAL CONFORMANCE TO CONTRACT DOCUMENTS ONLY. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRING AND CORRELATING DIMENSIONS AT JOBSITE FOR TOLERANCE, CLEARANCE, QUANTITIES, FABRICATION PROCESSES AND TECHNIQUES OF CONSTRUCTION, COORDINATION OF HIS OR HER WORK WITH OTHER TRADES AND FULL COMPLIANCE WITH CONTRACT DOCUMENTS.

> REVIEWED BY: RESIDENTIAL ENGINEERING, SERVICES, LLC


> > Brad Whuxol, P.E.



2nd Floor Truss Layout

Scale: 3/16'' = 1'

		HANGER SCHEDULE	Quantity		Lot 82 The Manor at Stoney Creek	4407 SW Amethyst Dr.		0		
	•	LUS24	7							
	•	LUS26	0							
		HUS26	10				MO			
	A	HHUS26-2	0				<u> </u>			
	_	HGUS26-2	0	S				424		
	A	HGUS28-3	0	MI	[anc			746-	2)	
		LTHJA26	0	SUMMIT HOMES	ot 82 The M		Lee's Summit	Chance 785-746-4240	Job # 400152	
		TJC37	2							
		TJC57	0							
	_	HTS20	0	S	Ľ	4	Ľ	Ü	Jo	
•	of the	angle denotes the the Truss as it appeared Draw ovided.	Customer	Job Name	Job Site Address	City, State	Designer	3/20/2020		



Unless otherwise specified by Engineer Of Record, Wheeler Lumber, LLC recommends an uplift connection at each bearing point per the following:


of Uplift Connector 0 - 495: (1) H2.5A 495 - 990: (2) H2.5A 990 - 1245: (1) HTS20

Installation per Simpson Strong-Tie guidelines.

For Reactions greater than 1245#, refer to EOR.

of the roof and floor system and for the overall structure. The design of the truts support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult "Bracing of wood trusses" available from the Truss Plate Institute, 583 D'Onifrio Drive; Madison, WI 53179.	Shop Drawing Approval	THIS LAYOUT IS THE SOLE SOURCE FOR FABRICATION OF TRUSSES AND VOIDS ALL PREVIOUS ARCHITECTURAL OR OTHER TRUSS LAYOUTS. REVIEW AND APPROVAL OF THIS LAYOUT MUST BE RECEIVED BEFORE ANY TRUSSES WILL BE BUILT. VERIFY ALL CONDITIONS TO INSURE AGAINST CHANGES THAT WILL RESULT IN EXTRA CHARGES TO YOU.
--	-----------------------	--

Wheeler Lumber 1959 Old Hwy 50 NE Waverly, KS 66871



RELEASE FOR CONSTRUCTION AS NOTED ON PLANS REVIEW DEVELOPMENT SERVICES LEE'S SUMMIT, MISSOURI

04/08/2020