

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182652
Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Inlets Clean	John DiMauro	Failed	Wednesday, April 08, 2020

Corrective Action Required:

1	Misc	A number of the storm curb inlets have silt, mud and construction debris built up in them. Please flush and clean the inlets out asap to avoid the debris from collecting and clogging the public storm water collection system.
---	------	--

Comments: