CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182652

Address: 2100 SW LADDERBACK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

DE - Street - Proof Roll John DiMauro Passed Thursday, April 09,

2020

Corrective Action Required:

1 Misc I observed the proof roll test for the FlyAsh treated sub-grade on all three

proposed streets. I verified the correct load weight and truck was used. There were a few sections in the lower lying "sump" areas of the roads that failed the test. The crew is going to make corrections to these areas and and

test again later this week.

Informational:

2 Misc The Spalding Excavating crew made corrections to the soft areas of the street

yesterday. I observed a second proof roll test this morning of the corrected

areas and the roll test passed.

Comments: