

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182604  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	Mark Harding	Partial	Thursday, April 09, 2020

Partial Correction:

1 Misc

GAS PIPING PRESSURE TEST & VISUAL INSPECTION ON:  
PIPING FROM COLUMN WRAP OUTSIDE FRONT ENTRANCE TO FIREPLACE ENCLOSURE; GAS PIPING FRMO EXTERIOR TO INSIDE POOL PUMP ROOM HOLDING 15 PSI;  
Exterior meter to front column.

**Comments:**