CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20182604Address:837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection	n:	Inspector:	Outcome:	Date:
Rough Fra Commerci	ming Inspection - ial	John Borns	Passed	Thursday, October 24, 2019
Partial Cor	rection:			
1	Misc	INSTALLATION OF ROOF SHEATHING: LEFT WING: SUBSTANTIALLY COMPLETED SOME OVER-DRIVEN LOCATIONS TO BE RE-NAILED;		

Comments: