

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Monday, November 18, 2019

Partial Correction:

1	Misc	INSTALLATION OF ROOF SHEATHING: LEFT WING: SUBSTANTIALLY COMPLETED -- SOME OVER-DRIVEN LOCATIONS TO BE RE-NAILED;
2	Misc	OK TO COVER SHEAR WALLS AT ENDS OF BLDG A: NORTH END OF LEFT WING;
3	Misc	DECK COLUMNS OK TO COVER AT: RIGHT WING;

Comments: