

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170399
Address: 3520 SW HOLLYWOOD DR, Unit:2, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, April 09, 2020

Corrective Action Required:

1	Misc	- 208 GFCI KITCHEN REFERGIRATOR & RANGE - - 300 DECK RAILING IN CORNER A 4" SPHERE SHALL NOT PASS THROUGH - - COMPLETE DOWNSPOUTS AT ENTRY DOORS - - PROVIDE SIDEWALKS AT REAR ENTRANCES -
---	------	---

Comments: