

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193585
Address: 2920 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, April 10, 2020

Corrective Action Required:

1	Misc	- PROVIDE 75% BEARING RAFTERS GREAT ROOM - PROVIDE ENGINEER REPORT
		- FIRE BLOCKING CEILING BASEMENT BATH - FIRE STOP AT DROP CEILING FUR DOWN IN BATHROOM

Comments: