

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172535
Address: 269 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Partial	Friday, April 10, 2020

Corrective Action Required:

2	FIRST FLOOR	BLDG # 17 WEST END GARAGE 15 SERVICE ENTRY CABLE NEEDS SUPPORTED OVER GARAGE AND ELEC ROOM, - - PROVIDE 6'8" HEAD ROOM HEIGHT ON ALL STAIRS CHECK ON FINAL - - 4/7/20 1ST FLOOR EAST END -
---	-------------	--

Comments: