

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192072
Address: 1537 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, April 10, 2020

Corrective Action Required:

1	Misc	- Reestablish erosion control around lot - Install anti tip device on range - Size attic access door in garage to seal against ceiling trim - Switch plate cover required at basement light switch - Complete final grade and sod - Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36"
---	------	--

Comments: