

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192859

Address: 492 NW CHIPMAN RD, LEES SUMMIT, MO 64086480 NW CHIPMAN RD, LEES SUMMIT, MO
64086470 NW CHIPMAN RD, LEES SUMMIT, MO 64086460 NW CHIPMAN RD, LEES
SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Hydrostatic Test	Joe Starlin	Failed	Friday, April 10, 2020

Informational:

1	Misc	4-10-20 We started the test at 2:45pm it will go for two hours at 200PSI.
---	------	---

Informational:

2	Misc	4-10-20 We started the test at 3:10pm it will go for two hours at 200PSI.
---	------	---

Informational:

3	Misc	4-10-20 We started the test at 3:10pm it will go for two hours at 200PSI. The test failed.
---	------	--

Comments: