

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192861
Address: 2919 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Monday, April 13, 2020

Corrective Action Required:

1	Misc	- PROVIDE TJC37 PER HANGER SCHEDULE TRUSS LAYOUT PATIO & GARAGE - - COVERED PATIO SHALL HAVE 1 ROOF VENT PER PLAN - - SEAL BORE BOTTOM PLATE LAUNDRY - - SEAL TOP PLATE ELECTRICAL JACK N JILL BATH - NAIL GUARD DEAD SPACE 2ND FLOOR HALLWAY - - GARAGE REAR WALL ANCHOR BOLT SHALL BE IN MIDDLE 1/3 OF WIDTH OF PLATE - - GARAGE MISSING NUTS WASHERS ANCHOR BOLTS - - PROVIDE PFH PORTAL FRAME PER PLAN GARAGE DOOR - HOOK UP EXHAUST FAN BATH AT MUD ROOM - - CANTILEVER AT FIRE PLACE TO TRIPLE JOIST -
---	------	---

Comments: