

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200416  
Address: 1198 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Failed	Monday, April 13, 2020

Corrective Action Required:

1 Misc

ABOVE CEILING-  
COVERED-OPEN CEILING TILES FOR INSPECTION OF NEW 2X4 LIGHTS, WIRES,  
SUPPORTS, CLIPS.

PLUMBING TO NEW DRINKING FOUNTAIN FOR ABOVE CEILING NEEDS  
INSPECTED.

HVAC EXISTING

**Comments:**