

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170397
Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, April 13, 2020

Informational:

1 Misc

Bldg # 1 -
-
3rd floor all rough complete -
- 2nd Floor complete

NE NW SW SE stairways 3rd & 2nd floors complete

Corrective Action Required:

2 Misc

- LOWER LEVEL GROUND FLOOR -
- VERTICAL DRAFT STOP EVERY 10' FOUNDATION WALL AT FURR OUT -
- FIRE CAULK ELECTRICAL TOP PLATE CORRIDOR NEAR 04 -
- 08 FIRE CAULK DRAINS AT DEAD SPACE TUB & LAUNDRY, FIRE CAULK REFRIGERATOR LINE TOP PLATE -
- 10 BOCA PLACE IN CLOSET NEAR SHOWER PAN -
- 04 SEAL BORE TOP PLATE SHOWER BATH -
- 02 FIRE CAULK DRAIN DEAD SPACE LAUNDRY -
- 00 BEDROOM HOLD DOWN NEAR WINDOW, ANCHOR BOLTS DINING ROOM UNDER WINDOWS, FIRE CAULK SERVICE ENTRY CABLES, ELEC & PLUMBING IN TRUSS SEPERATION WALLS -

Comments: