

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193585
Address: 2920 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, April 14, 2020

Corrective Action Required:

1	Misc	- PROVIDE 75% BEARING RAFTERS GREAT ROOM - PROVIDE ENGINEER REPORT
		- EMAIL ENGINEER REPORT TO BE ATTACHED TO PERMIT - DEV.MainLine@cityofls.net-
		- Michael Harkins 04/14/2020 10:06 AM

Comments: