

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170396
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Tuesday, April 14, 2020

Corrective Action Required:

1	Misc	-Provide barrier around pool that does not allow a 4" object through the fence. 2 locations southeast side at the stairs . and northeast side at the upper level where fence heads south to building. - Plaque required on Pool equipment room. " POOL EQUIPMENT ROOM"
---	------	--

Comments: