

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191389  
Address: 2605 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Wednesday, April 15, 2020

Corrective Action Required:

1	Misc	- PROVIDE AS GRADED PLOT PLAN - - PROVIDE FINAL GRADE, SOD, SPLASH BLOCKS - - RAISE GRADE TO 30" OR PROVIDE GUARDRAIL TOP STEP AT STOOP -
---	------	---

Comments: