

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191391  
Address: 1837 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Wednesday, April 15, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- PROVIDE FINAL GRADE, SOD , SPLASH BLOCKS -</li><li>- SEAL TOP OF METER CAN A/C DISCONNECT -</li><li>- INSTALL A/C CONDENSOR -</li><li>- INSTALL DISHWASHER -</li><li>- PROVIDE HAMMER ARESTORS DISHWASHER &amp; WASHING MACHINE -</li><li>- PROVIDE 3 GFCI RECEPTACLES GARAGE -</li><li>- PROVIDE GFCI PROTECTION DISHWASHER &amp; WASHING MACHINE -</li><li>- PROVIDE ANTO SIPHON DEVICE HOSE BID MAIN SHUTOFF -</li><li>- SUMP PUMP &amp; DISCHARGE 36" FROM FOUNDATION -</li></ul>
---	------	---

Comments: