

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193347
Address: 2021 NE BLUESTONE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, April 15, 2020

Corrective Action Required:

1 Misc

FRAMING:

- Provide min R-19 thermal envelope at garage ceiling return air space
- Install support under roof strut above 1st fl front bedroom window

MECHANICAL:

- Support flexible duct above hallway outside master bed

Comments: