CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRSITE20192792Address:2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	on:	Inspector:	Outcome:	Date:
DE - Proo	f roll parking lot	John Jackson	Partial	Wednesday, April 15, 2020
Corrective Action Required:				
1	Misc	Approximately 70% of parking lot passed proof roll. Contractor plans to remove top surface and use gravel rock for stabilizing of surface. 4/14/20		
Informational:				
2	Misc	Contractor was able to stabilize area of concern. Contractor has passed subgrade proof roll.		

Comments: