

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20191389
Address: 2605 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082
Inspected On: Wednesday, April 15, 2020
Inspected By: Michael Harkins
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Wednesday, April 15, 2020

Corrective Action Required:

1	Misc	- PROVIDE AS GRADED PLOT PLAN - - PROVIDE SOD, SPLASH BLOCKS - - RAISE GRADE TO 30" OR PROVIDE GUARDRAIL TOP STEP AT FRONT DOOR -
---	------	--