

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172513
Address: 229 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, April 15, 2020

Corrective Action Required:

1	Misc	- PROVIDE TAMPER PROOF CAPS ALL A/C CONDENSORS - - OK FOR TCO WHEN PARKING ISSUES RESOLVED- Michael Harkins 04/15/2020 1:50 PM
---	------	--

Comments: