

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20173051  
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Khanh Nguyen	Failed	Wednesday, April 15, 2020

Corrective Action Required:

1	Misc	COVERED WALKWAY PIERS: MIN 36" DOWN TO FROST DEPTH AND TO BEARING SOIL, INSTALL 12 #5 VERTICAL REBARS
---	------	---

**Comments:**