

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170397
Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Passed	Thursday, April 16, 2020

Informational:	
1 Misc	Bldg # 1 - - 3rd floor all rough complete - - 2nd Floor complete NE NW SW SE stairways 3rd & 2nd floors complete

Corrective Action Required:	
3 STAIR TOWER 1	1st layer type C OK 2ND LAYER TYPE C OK 3RD LAYER TYPE C & RC CHANNEL OK

Corrective Action Required:	
4 STAIR TOWER 2	1st layer type C OK 2ND LAYER TYPE C OK 3RD LAYER TYPE C & RC CHANNEL OK

Corrective Action Required:	
5 STAIR TOWER 3	1st layer type C OK 2ND LAYER TYPE C OK

Corrective Action Required:	3RD LAYER TYPE C & RC CHANNEL OK
6	STAIR TOWER 4
	1st layer type C OK
	2ND LAYER TYPE C OK
	3RD LAYER TYPE C & RC CHANNEL OK

Comments: