

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20170397  
Address: 3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Partial	Thursday, April 16, 2020

Informational:	
1 Misc	2nd LAYER TYPE C 3RD FLOOR UNITS & STAIRWAYS

Informational:	
2 Misc	screw pattern 2nd floor units walls & ceilings OK

Informational:	
3 STAIR TOWER 1	1st layer type c OK 2ND LAYER TYPE C OK 3RD LAYER TYPE C & RC CHANNEL OK

Informational:	
4 STAIR TOWER 2	1st layer type c OK 2ND LAYER TYPE C OK 3RD LAYER TYPE C & RC CHANNEL OK

Informational:	
5 STAIR TOWER 3	1st layer type C OK 2ND LAYER TYPE C OK 3RD LAYER TYPE C & RC CHANNEL OK

Informational:	
6 STAIR TOWER 4	1st layer type C OK 2ND LAYER TYPE C OK 3RD LAYER TYPE C & RC CHANNEL OK

**Comments:**