

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182387
Address: 2023 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Failed	Thursday, April 16, 2020

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	rooms approved for top rock of roof truss. ; 101-05,115-118; Above hard lids (attic) living quarters approved 3/23/20 HARDCEILING: FIRE CAULK ALL PENETRATIONS AT FIRE WALL LOCATIONS WHERE HARD LID CONNECT.
---	----------------------------------	--

Comments: