



April 14, 2020

New Mark Homes

Re: 1908 River Run Road
Whispering Woods, Lot 6
Permit # PRRES20193663

Apex Engineers, Inc. observed the preparations of the garage and basement slabs for the proposed house located at the above referenced address.

The garage and basement slabs will be structural with a gravel base course. The forms and reinforcing steel were found to be clean, well aligned, properly supported and in compliance with the design.

Note:

- The inspections were performed at 10:30 am
- At the time of the inspection the temperature was 41°
- Erosion control was installed at the time of our firms site visit.

Our firm recommends approval of the garage and basement slabs for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction.

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel. If changes in the condition of the site occur and Apex Engineers, Inc. is not allowed the opportunity to re-evaluate the site to respond to any of these changes, our firm cannot be responsible for the effect of any of the conditions that differed from those reported herein.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,
Apex Engineers, Inc.

Kevin Miller
Engineering Technician

Clayton J. Hess, P.E.
Principal

