

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Air Test	Ronald Paynter	Partial	Thursday, April 16, 2020

Informational:

1	Misc	The following sanitary lines passed their air test: manhole existing 28-208 to 1-1, 1-1 to 1-2, 1-2 to 1-3, 1-3 to 1-4, and 1-4 to 1-5. RP 1-7-2020
---	------	---

Informational:

2	Misc	The following sanitary lines passed their air test. Manholes 1-5 to 1-6, 1-6 to 1-7, 1-7 to 3-1 and 3-1 to 3-2. RP 2-7-20
---	------	---

Informational:

3	Misc	The following sanitary lines passed their air test: 1-7 to 1-8, 1-8 to 1-9, 1-9 to 1-10, 1-10 to 1-11, 1-11 to 1-12, 1-12 to 1-13 and 1-10 to 4-1. RP 3-5-20
---	------	--

Informational:

4	Misc	The following sanitary lines passed their air test: 1-7 to 1-8, 1-8 to 1-9, 1-9 to 1-10, 1-10 to 1-11, 1-11 to 1-12, 1-12 to 1-13 and 1-10 to 4-1. RP 3-5-20
---	------	--

Corrective Action Required:

5	Misc	The following sanitary line failed the air test: 8-1 to 8-2. Jim Weers thinks he knows what could have caused the failed test. We will retest the line again in the future. RP 3-6-20
---	------	---

Informational:

6	Misc	The following sanitary lines passed their air test: 8-0 to 8-1, 8-2 to 8-3, 8-3 to 8-4, 8-4 to 8-5, 8-5 to 8-6 and 8-6 to 8-7. RP 3-6-20
---	------	--

Informational:

7	Misc	The following sanitary lines passed their air test: 11-5 to 11-4, 11-4 to 11-3,
---	------	---

11-3 to 11-2, 11-2 to 11-1 and 11-1 to existing MH 28-103. RP 4-14-20

Informational:

8 Misc

The following sanitary lines passed their air test: Existing manhole 28-100 to 10-1, 10-1 to 10-2, 10-2 to 10-3, 10-3 to 10-4, 10-4 to 10-5, 11-3 to 12-1, 12-1 to 12-2, 12-2 to 12-3, 12-3 to 12-4, 12-4 to 12-5 and 12-1 to 13-1. RP 4-16-20

Comments: