

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20193321	Date:	April 17, 2020
Project Title:	ROSS DRESS FOR LESS	Applicant:	
Location:	480 NW CHIPMAN RD, LEES SUMMIT, MO 64086		
Type of Work:			FIRE & SECURITY SOLUTIONS GROUP INC
Occupancy Group:	M		11240 STRANG LINE RD
Description:	TENANT FINISH FOR CLOTHING		LENEXA, KS 66215-4039
SALES ROSS DRESS FOR LESS		Primary:	(913) 789-7160
Construction Type:	Type IIB (Unprotected)		
Map Page:	195B		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.