

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193105
Address: 1505 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, April 20, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- anchor bolt rear corner garage- H 2.5 covered patio -- torn bathroom exhaust fan discharge line 1st floor bath and basement bath- fire blocking 2 x 6 wall at stair landing -- anchor bolts steel column mech room -- dbl joist hanger above steel column basement stairs -- (3) 2 x 10 joist beam to beam column C per plan -
---	------	--

Comments: