

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192858
Address: 1527 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, April 21, 2020

Corrective Action Required:

1	Misc	-ELECTRICAL - - REMOVE BONDING SCREW FROM SUB PANEL - -TIGHTEN ANCHOR BOLTS BASEMENT - - seal DEAD SPACE NEAR BATH FRONT BEDROOM - - EC#2 PROVIDE 800 LB HOLD DOWNS Upper level PER PLAN - - ADDRESS BEAM IN BASEMENT CORNER NEAR WINDOWS (3) 2 X 6 STUD PACK lands on 2 one of which 1/2 lands on bottom plate -
---	------	---

Comments: