

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191955
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|-------------------------|
| Footing Inspection - Commercial | Khanh Nguyen | Partial | Tuesday, April 21, 2020 |

Corrective Action Required:

1 Misc

****FOOTING INSPECTED BY 3RD PARTY (NOT INSPECTED BY CITY) SHALL BE APPROVED BY ENGINEER OF RECORD AND DOCUMENT SUBMITTED TO THE CITY**

FROST FOOTING INSPECTED BY CITY-OK TO POUR: FROM E/20 CW TO L/2; U/1 TO X/1. UFER REBAR INSTALLED NEAR SERVICE LOCATION AT X/1

SW AND NE STAIR ENCLOSURE FOOTINGS OK

INTERIOR FOOTING: FOOTING LINE 5 TO 19-OK

Comments: