

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192780  
Address: 460 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Michael Harkins	Partial	Tuesday, April 21, 2020

Corrective Action Required:

1	Misc	(2) prefab light pole base SE corner of bldg conduit in trench OK to cover 3/31/20 (4) piers for prefab light pole bases east along Donovan 4/8/20 # 5 #6 #7 OK to cover conduit at drive on Donovan. DONAVAN SIDE-
		SOUTH FACE PARKING LOT- EAST TO WEST 2,3,4,5,6,7, SOUTH PARKING LOT WEST SIDE (4) PRECAST POLE BASES, GROUND RODS, CONDUIT OK TO COVER SOUTH PARKING LOT WEST END (2) JOB TRAILER, (2)STORE FRONT - (4) PRECAST POLE BASES,GROUND RODS, CONDUIT OK TO COVER - 4/16/20 underground conduit electrical room at trash enclosure to pole base at entry on donovan OK to cover - 4/21/20 conduit main electrical room to rear corner of building to jbox for pole bases OK to cover -

Comments: