

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193591
Address: 117 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Michael Harkins	Failed	Wednesday, April 22, 2020

Corrective Action Required:

1	Misc	- (2) 18 X 36 PIERS - - PLANS ON SITE SHOW 20 X 36 PIER BETWEEN THE (2) INSPECTED -
---	------	--

Comments: