

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190679
Address: 222 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Monday, December 02, 2019

Corrective Action Required:

1	Misc	IN-WALL AT PERIMETER WALLS: 1ST FLOOR: NOT READY; SOME HOLD-DOWN DEVICES NOT INSTALLED IN UP-DOWN PAIRS
---	------	---

Comments: