

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191159
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	John Borns	Partial	Monday, December 16, 2019

Partial Correction:

1 Misc

NO ISSUES FOUND ON EQUIPOTENTIAL BONDING AT:
POOL BOTTOM SLAB - LEADS STUBBED UP ABOVE POUR LINE;

Comments: