

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193135
Address: 2920 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, April 22, 2020

Corrective Action Required:

1	Misc	- PROVIDE ANCHOR BOLTS AT SLIDING GLASS DOOR BASEMENT - - SCH 40 COLUMNS BASEMENT 4.5 & 5 NOT PER PLAN - - PROVIDE BOLTED CONNECTION STEELS GARAGE PER PLAN - - PROVIDE BLOCKING AT SHEATHING BREAKS GARAGE PORTAL FRAMING - - SNOW BLOCKING NEAR BOOTOM PLATE BED # 1 - - ADDRESS NOTCHED LVLs BED # 2 & BATH -
---	------	---

Comments: