

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193179  
Address: 2400 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, April 22, 2020

Corrective Action Required:

1	Misc	- PROVIDE ROOF BOOTS VTR BATH AT ENTRY - - PROVIDE FIRE BLOCKING BED # 2 - - ANCHOR BOLTS SHALL BE IN MIDDLE 1/3 OF THE WIDTH OF PLATE BED # 3 -
---	------	--

**Comments:**