

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193179  
Address: 2400 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:      | Outcome: | Date:                     |
|---|-----------------|----------|---------------------------|
| <b>All Rough Inspection - Residential</b> | Michael Harkins | Failed   | Wednesday, April 22, 2020 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | - PROVIDE ROOF BOOTS VTR BATH AT ENTRY -<br>- PROVIDE FIRE BLOCKING BED # 2 -<br>- ANCHOR BOLTS SHALL BE IN MIDDLE 1/3 OF THE WIDTH OF PLATE BED # 3 - |
|---|------|--|

**Comments:**